



NOTE:

1. TRENCH SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH WSDOT 7-08.3(3).
2. BEDDING MATERIAL SHALL BE PEA GRAVEL OR APPROVED EQUAL. PIPE ZONE BACKFILL SHALL BE PEA GRAVEL (OR APPROVED EQUAL) TO THE SPRING LINE FOR RIGID PIPE AND TO A DEPTH OF 6" ABOVE THE CROWN FOR FLEXIBLE PIPE AS SHOWN ABOVE.

Approved:

City Engineer

June 17, 2005

Date

STORM DRAIN STANDARD DETAIL



Dwg No:

SD1

TYPICAL STORM DRAIN
PIPE TRENCH SECTION